

East Notice Certification Service Co., Ltd.

317/319 3/F, HuiCheng Building, XiangPu Street, DongPu, TianHe, Guangzhou

Tel:+86-020-2331 4234 Fax:+86-020-8256 8534 E-mail:enc@enc-lab.com Web: www.enc-lab.com

TEST RESULT CERTIFICATE

Registration No. : ENC110509VN73

Certificate Holder : Remak Construction and Interior JSC

No14 Lot B, The Le Duc Tho Auction, My Dinh, Tu Liem

Hanoi, Vietnam

Product Designation : Remak™ Wood wool

Model Name : 600*600*15mm

Brand Name : REMAK

Manufacturer : Remak JSC

No14 Lot B, The Le Duc Tho Auction, My Dinh, Tu Liem

Hanoi, Vietnam

Test Methods: EN ISO 354: 2003 Acoustics - Measurement of sound absorption in a

reverberation room.

The absorption class was determined in conformance with EN ISO

11654:1997

Weighted sound absorption coefficient

Test Results : $\alpha_w = 0.78$,

Sound absorption class: B

-

Issue Date: May 12, 2011

Ray Prou / General Manager

Recognized by East Notice Certification Service Co., Ltd. in accordance with the EN ISO 354: 2003 standard and EN ISO 11654:1997 the absorption class A. The certificate doesn't imply assessment of the production. The certificate is only applicable to the equipments described above. This certificate shall not be re-produced except in full without the written approval of East Notice Certification Service Co., Ltd.

Note: This certificate is part of the full test report(s) and should be used in conjunction with it.